



## Park City Water System Tank Inspection and Cleaning

### ADDENDUM 1

DATA UPDATE :

Tank Name:	Capacity (gal):	Diameter/Dimensions (ft)	max depth	tank type	hatch size	special considerations	planned cleaning date
Spiro WTP Finish #1	10,000	6 x 36	15.00	indoor concrete	40" x 36"	pumps in tank	2018
Spiro WTP Finish #2	280,000	45 x 60	15.00	indoor concrete	40" x 36"	pumps in tank	2018