

LEGEND AND APPROVED PARTS LIST

| ITEM | DESCRIPTION | ACCEPTABLE MANUFACTURER | MODELS |
|------|--|-------------------------------|--|
| ① | 5' DIA. MANHOLE, PRECAST CONCRETE ECCENTRIC CONE AND WALL SECTIONS | | ASTM C 478 |
| ② | METER VAULT FRAME AND COVER (STD. PLAN 529) | | |
| ③ | POLYPROPYLENE ENCASED GRADE 60 STEEL STEPS AT 13" C-C, 13-1/2" TREAD WIDTH | M.A. INDUSTRIES OR APPV'D EQ. | PS2-PFDF |
| ④ | 2" CURB VALVE, F.I.P. x CTS | MUELLER | B-25172N |
| ⑤ | 2" DIA. BRASS NIPPLE x 3" LENGTH, M.I.P. (5 EA) | | |
| ⑥ | 2" DIA. BRONZE TEE, F.I.P., THREADED | | |
| ⑦ | 2" BRONZE 90° ELBOW, F.I.P., THREADED (2 EA) | | |
| ⑧ | 2" BRONZE UNION, F.I.P., THREADED (2 EA) | | |
| ⑨ | 1-1/2" BRASS NIPPLE x 4" LENGTH, 2" x 1-1/2" BRONZE BELL REDUCER, AND 1-1/2" CLOSE BRASS NIPPLE (2 EA) | | |
| ⑩ | 1-1/2" METER YOKE (2 EA) COMMERCIAL SERVICE: WITH BYPASS RESIDENTIAL SERVICE: WITHOUT BYPASS IRRIGATION SERVICE: WITHOUT BYPASS | MUELLER | 1-1/2"x15" B2423-2-01N (WITH BYPASS) 1-1/2"x15" B2422N (WITHOUT BYPASS) |
| | | FORD | 1-1/2" VBHH76-15B-11-66-NL (WITH BYPASS) 1-1/2" VBHH76-15-11-66-NL (WITHOUT BYPASS) |
| ⑪ | 2" CONNECTION, F.I.P. x CTS; 2" BRASS NIPPLE x 4" LENGTH; 2"x1-1/2" BRONZE BELL REDUCER; AND 1-1/2" CLOSE BRASS NIPPLE (OUTLET) (2 EA) | MUELLER | H-15451N |
| | | FORD | C-14-66-G-NL |
| ⑫ | METER, SUPPLIED AND INSTALLED BY PCMC (2 EA) | | |
| ⑬ | PIPE SUPPORTS (4) 16"X8"X8" CMU BLOCK, (2) METER SUPPORT RODS, GALVANIZED | | |
| ⑭ | MXU AND WIRING, SUPPLIED AND INSTALLED BY PCMC | | |
| ⑮ | MXU REMOTE LOCATION CONDUIT WITH END CAPS, SCH 40 PVC (STD. PLAN 531) | | |
| ⑯ | END CAP AND MARKER, CTS X F.I.P. (OUTLET) (2 EA) | | H-15451N AND H-10035N |

DETAIL NOTES

1. LOCATE METER VAULT PER APPROVED PLANS AND SET METER BOX PLUMB
2. SST INSERT STIFFENERS REQUIRED ON ALL CTS TUBING CONNECTIONS

| | | | |
|--|-------------|---|------------------|
|  PARK CITY MUNICIPAL CORPORATION WATER | DATE | 1-1/2" DUAL METERS OUTSIDE SETTING | STD. PLAN |
| | 4/2014 | | 525 S |
| | REV. | | |
| | | | |