Addendum 1

Response to Questions

Leak Detection

Issued 12/19/2017

- 1. What is the approximate age range of the pipe in this system or area? See Table 1 at the end of this addendum.
- 2. Would you allow contractors to work on weekends? Probably not.
- 3. Are the customer meters located in pits or inside of residents' houses? Primarily in pits.
- 4. Are the customer meter/curb valve chambers easily identified and accessible? Customer meters are generally identifiable and accessible. Curb Valves are generally inaccessible.
- Do the meter/curb valve chambers in the survey area have locking lids?
 Most boxes have a stand worm lock with nut on top to hold the box in place. Please see our Water Standard Plans for more information.
 http://www.parkcity.org/home/showdocument?id=13185
- 6. What are the average depths and the deepest depth of water lines/ valve chambers?

 Most water lines and valves are located 5-8 feet deep. Though rare, the deepest water lines are 20 feet deep.
- 7. What is the estimated water loss percentage for this system or area? Water loss was 25% in 2013.
- 8. Have you conducted an AWWA water audit and if so will you please provide that information? Yes in January 2017. That data will not be provided at this stage of procurement.
- 9. When was the last leak detection survey conducted on this system or area? More than 10 years ago.
- 10. Will you any supply the documentation or findings from the last survey? No.
- 11. What are the results from previous bids, if any, for this scope of work?

 Two leak detection RFP's were released in December. Prior to this the last RFP for leak detection was more than 5 years ago. Any prior responses the City may have will not be included.
- 12. What is the general time expectation for found leaks to be repaired by the utility? Undetermined at this time.

Table 1.

Year	Pecentage	Length	1992	3.04	20,357
Unknown	20.54	137,544	1993	0.08	526
1965	0.52	3,513	1994	1.53	10,232
1968	0.03	225	1995	1.71	11,442
1970	0.95	6,364	1996	1.91	12,798
1971	1.39	9,306	1997	1.08	7,217
1972	2.60	17,393	1998	0.13	839
1973	0.66	4,424	1999	0.68	4,581
1974	1.44	9,645	2000	3.91	26,211
1975	2.26	15,166	2001	1.20	8,021
1976	1.27	8,489	2002	3.27	21,891
1977	1.70	11,387	2003	0.50	3,327
1978	3.80	25,442	2004	0.83	5,570
1979	1.73	11,574	2005	3.49	23,370
1980	4.19	28,054	2006	2.75	18,409
1981	3.35	22,442	2007	1.25	8,366
1982	2.03	13,579	2008	0.79	5,298
1983	3.55	23,752	2009	0.89	5,946
1984	4.10	27,479	2010	1.48	9,925
1985	0.22	1,488	2011	0.14	914
1986	0.34	2,284	2012	0.49	3,291
1987	0.15	1,005	2013	1.17	7,848
1988	1.30	8,711	2014	2.14	14,320
1989	3.08	20,651	2015	0.68	4,560
1990	1.98	13,247	2016	0.11	729
1991	1.31	8,743		99.73	667,896