



**PARK CITY MUNICIPAL CORPORATION**

**ADDENDUM No. 1  
to  
3KWTP-001-PQ UV Disinfection System**

**March 04, 2019**

This Addendum No. 1 consists of the following clarification to Part 2, Attachment "C". It is the responsibility of the Proposer to incorporate, as applicable, this addendum information in the proposal response. The Proposal Date has not changed as part of this addendum.

**Clarifications**

Question 1: Can you provide information on what the expected design UVT is going to be?

Answer: Based off historical UVT data, a min/avg/max UVT of 95/98/99%.

Park City Municipal Corporation

A handwritten signature in blue ink, appearing to read "Roger McClain".

Roger McClain  
Park City Public Utilities Engineering Manager